

# DECLARATION OF PERFORMANCE Ref: DOP BB-49 - IRAGMB600

Unique identification code of the product-type:

#### **IRAGMB600**

- 1. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
- 2.

### 600x600mm Brushed Brass and Gunmetal Towel Rail -Iraya

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

### In Heating Systems in Buildings

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):



Buy It Direct, Trident Business Park, Leeds Road, HD2 1UA

Buy It Direct - The Black Church, St Mary's Place, Dublin 7

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

### Not Applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

### System 3

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard.

BS EN442-1:2014



## 8. Declared performance:

Essential Characteristics	Performance	Harmonised Technical Specification
Reaction to Fire	A1	
Release of Dangerous Substances	None	
Surface Temperature	70°C	
Resistance to Pressure	No breakage at 1,69x MOP (0.5)	
Rated Thermal Outputs	$\Phi_{30}$ 158W/539BTU $\Phi_{50}$ 290W/989BTU	BS EN442:2014
Thermal Output in Different Operating Conditions (Characteristic Curve)	Φ=2.82x△T1.18	
Durability as:		
Resistance Against Corrosion	No corrosion after 100h Humidity	
Resistance Against Minor Impact	Class 0	

- 9. We hereby declare that the products named above have been designed, are produced and have been tested to comply with relevant sections of the above referenced standard and
  - Regulation (EU) No, 305/2011
  - Construction Products (Amendment etc.) (EU Exit) Regulations 2020 SI 2020/1359

Signed for and on behalf of the manufacturer:

Craig Watson (QA Manager) - 19.6.25